



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 06/13/2022
Received: 05/31/2022
Sampled By: Mathew Spear
Work Order: 2151003

C L I E N T Environmental Inspection Services

Attn: Charles Spear
11981 Fargo Rd
Aurora OR, 97002
Phone: (503) 680-6398

Project: ESD LIW
Project # : -
Sample Type : Grab

Sampling Location: Jefferson ESD

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
2151003-01	Sample Name: 2049ESD- 008SF22A Sampled: 5/27/22 14:10 Sample Composition: Raw Single						Matrix: Drinking Water
†Lead	1030	EPA 200.9	4	ppb	1	15 ppb	06/08/22 16:41
2151003-02	Sample Name: 2049ESD- 009BF22A Sampled: 5/27/22 14:10 Sample Composition: Raw Single						Matrix: Drinking Water
†Lead	1030	EPA 200.9	4	ppb	1	15 ppb	06/08/22 16:41
2151003-03	Sample Name: 2049ESD- 010BF22A Sampled: 5/27/22 14:10 Sample Composition: Raw Single						Matrix: Drinking Water
†Lead	1030	EPA 200.9	2	ppb	1	15 ppb	06/08/22 16:41

ND = None detected at the MRL **MRL** = Minimum Reporting Limit **MCL** = Maximum Contamination Limit

†All procedures for this analysis are in accordance with NELAP standards.

* The EPA MCL for Lead in Public Drinking Water Systems is 15 ppb; this is a maximum contamination level for lead in samples, this is not an acceptance level for health based exposure.

Note: Please make sure to send your results to the appropriate agency; Alexin Analytical does not forward these results to any program or person other than the above listed client. It is your responsibility to make sure these results get sent to whichever agency, city, or organization has requested them if these results are for compliance purposes.

Approved by: _____


Adriana Gonzalez-Gray
Laboratory Director